



**THE INSTITUTE OF  
Company Secretaries of India**  
**भारतीय कम्पनी सचिव संस्थान**  
**IN PURSUIT OF PROFESSIONAL EXCELLENCE**  
Statutory body under an Act of Parliament  
(Under the jurisdiction of Ministry of Corporate Affairs)

**CLARIFICATIONS TO THE QUERIES RAISED DURING PRE-BID MEETING HELD ON  
18.02.2021**

Followings are the Clarifications to the queries raised during Pre-Bid meeting held on 10th February, 2021 w.r.t. to the Tender dated 18.02.2021 for **“DESIGN, SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF ROOF TOP SOLAR POWER SYSTEM AT ICSI-MYSURU CHAPTER PREMISES.”**

Sl. No.	Queries raised by Participants	Clarification Given by Institute
1.	The EMD exemption for MSME registered bidders (Pg. No. 02 Clause no. 3. I). of Section II”)	As per tender documents only.
2.	Modification on the payment terms	As per tender documents only.
3.	Modifications of Pg. No.22 Clause no. 14. For regarding of cleaning of solar Modules/ arrays on every monthly least twice time.	Regular Maintenance including Cleaning of the Panels/ Modules/ Arrays to be done regularly to ensure trouble free operation of the system during Defect Liability period as well as AMC period
4.	The Custom fabricated Steel structures with enamel paint in mounting of Array Structure (Pg. No. 26 Clause no. 2 of Section- VII)	The Array Mounting Structure may be fabricated by using Structural Steel of Makes TATA or SAIL or RINL only. Supporting documents/ certificate of steel /Galvanisation to be submitted before execution.
5.	Remove the clause No. 19. b). of Section- VII “Module mounting structure- Certificate from MNRE approved test centre”	Further, structural stability certificate for design of the structure w.r.t to material/ size and to with stand wind load / pressure as per the region/ location to be submitted.
6.	Remove the clause No. 8 of Section- VII “INTEGRATION OF PV POWER WITHGRID” Because the plant capacity is too small	As per tender documents as this is as per MNRE guidelines
7.	Remove the clause No. 9 of Section- VII “DATA ACQUISITIONS SYSTEM/ PLANT MONITORING” Because the plant capacity is too small	As per tender documents as this is as per MNRE guidelines

8.	Add IEC / BIS Certification report in clause No. 19. c). of Section- VII “Inverter: Certificate from MNRE approved test centre.”	As per Tender documents only.
9.	Add the IEC / ISI/ BIS Certification report in clause No. 19. d). of Section- VII “DC Cable- TUV Certification.”	As per Tender documents only.
10.	Additional makes to be Approved in “List of Makes” for Mono-Crystalline Solar Cells.	As per Tender documents only.
11.	Additional makes to be Approved in “ List of Makes” for Inverter	As per Tender documents only.
12.	Additional makes to be the Approved in “ List of Makes” for MCCB,MCBs: ABB/ Siemens/ Schneider Electric/L&T	Additional make for MCCB,MCBs in “ list of makes”: Havells is acceptable

\*Above will be part of the Tender Documents.

Other terms & conditions of Tender Notice published/uploaded in Institute’s website on 10<sup>th</sup> February, 2021 for above mentioned project will remain same.

Interested Tenderers may take note of the above changes.

**Date: 19.02.2021**

**The Chairperson,  
Mysuru Chapter  
The ICSI**